

Refnr.	Arkivkode	Saksnr.	Saksbehandler	Dato
RRBD7339	GID 68/84	2021/9865	Magnus Jahren Fludal	Kopervik, 01.02.23

## Result from Public sewage pipeinspection

This letter is sent in referance to the meeting with the owners of 68/84 on the date 01.02.23 to clarify a issue regardig the shared pipe with 68/144.

Report with result from the pipe inspection is attached.

The shared pipe is made of PVC except for a section starting at 12.50 meters from the septic tank belonging to 68/144 and ending at 15.10 meters. This section is made of concrete, concrete does not fulfill Karmøy kommunes requirements for density.

There are currently two houses connected to this pipe; 68/84 Øvre eidevegen 23 and 68/144 Øvre eidevegen 25.

The owner of 68/82, Øvre Eidevegen 21 has expressed intention to connect his sewage to this shared pipe in the future.

Med hilsen  
Karmøy kommune

Magnus Jahren Fludal  
Saksbehandler  
Sektor vann, avløp og renovasjon

*Dokumentet er elektronisk godkjent og har derfor ingen signatur*

Vedlegg

\* Reports\_Sharedpipe\_68-84\_and\_68-144\_.pdf  
\* kart\_Sharedpipe\_68-84\_and\_68-144\_.pdf

### Adresseliste:

Navn	Adresse	Postnummer	Sted
EIDE KRISTBJØRG	Øvre Eidevegen 23	4250	Kopervik
RASCHICK RALPH MICHAEL	2001 HAMILTON ST #1724 USA	19130	PHILADELPHIA

